



1.	ROOFING AS SPECIFIED
2.	SLAB REINFORCEMENT 6x6 WWM OR LONG. & TRANS. REBAR
3.	BEND BOTTOM LONGITUDINAL REINFORCEMENT INTO SLAB AS SHOWN
4.	RIDGE BEAM REINFORCEMENT AS SPECIFIED
5.	QUAD-DECK PANEL SPAN EAVE TO RIDGE
6.	CONCRETE TO BE CALLED BY THE ENGINEER OF RECORD
7.	SLAB THICKNESS RANGE 2" - 6"
8.	QUAD-DECK PANEL THICKNESS: 7", 8", 9", 10", 11" 12", 12½"
9.	INSULATION LIP THICKNESS 2"
10.	CHECK LOCAL BUILDING CODE REGARDING EXPOSED FOAM INSULATION IN ATTICS
11.	15MIN. STAY IN PLACE CEILING FINISH (1/2" GYPSUM WALLBOARD OR SIMILAR)
12.	INSULATION AS SPECIFIED
13.	JOISTS AS SPECIFIED

QUAD-LOCK
Building Systems Ltd.

Quad-Lock Building Systems Ltd.
7398 - 132nd Street
Surrey, BC V3W 4M7
Canada

888.711.5625 - Toll Free
604.590.3111
604.590.8412 - fax
www.quadlock.com

IT IS THE RESPONSIBILITY OF THE USER TO COMPLY WITH ALL APPLICABLE REGULATIONS AND BUILDING CODE REQUIREMENTS CONCERNING THE USE OF THESE PRODUCTS.
IT IS FURTHER THE RESPONSIBILITY OF THE USER TO RESEARCH AND UNDERSTAND SAFE METHODS OF USE AND HANDLING OF THESE PRODUCTS.

DROPPED RIDGE BEAM DETAIL

DATE:	2009-01-21	SCALE:	NOT TO SCALE
REVISION NO:	R-02	PROJECT:	
REVISION DATE:	2009-07-10	CUSTOMER:	
DRAWN BY:	Z. PROSTRAN	APPROVED BY:	H.M.K. & D.J.B.
		DRAWING NO:	QD-210